



- NOTES:
- 1). OVERLOAD RELAY SETTING: MOTOR FLC X 0.58.
 - 2). X2 TERMINAL GROUNDED AS STANDARD, REMOVE IF NOT REQUIRED.
 - 3). MI STANDS FOR MECHANICAL INTERLOCK.
 - 4). TIMING RELAY TR: RZ7-FSY2D

5	GENERAL REVISION	4-24-12	MR
REV	DESCRIPTION	DATE	APP'D
DESIGNED EAP	REDUCED VOLTAGE STARTER WYE DELTA - CLOSED TRANSITION REMOTE START-STOP PUSHBUTTONS	sprecher+schuh HOUSTON, TEXAS DWG. NO. CAYT WS-108-01 SERIES 100	
DRAWN EAP			
APPROVED PAB			
DATE 4-9-90			